



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5181CS0161

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DEKOTEC GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DEKOTEC GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	greasing and sealing materials: Coatings for steel tubes (5181)
Product Description <i>Produktbezeichnung</i>	corrosion prevention coating with primer
Model <i>Modell</i>	BUTYLEN-AS39P mit BUTYLEN-HT Primer
Test Reports <i>Prüfberichte</i>	laboratory control test: 21-01029-KP02- from 12.07.2022 (EBI) supplement test: 16/146/5180/1_5_V2 from 24.05.2017 (EBI) type testing: 16/146/5180/1_5 from 18.04.2017 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN ISO 21809-3 (01.08.2016)

Date of Expiry / File No. 18.04.2027 / 22-0364-GNV
Ablaufdatum / Aktenzeichen

14.10.2022 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com

info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
BUTYLEN-AS39P mit BUTYLEN-HT Primer	permanent operating temperature: up to +50 °C designation according to standard: coating DIN EN ISO 21809-3 type: 12-1	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

handling: cold handle protection tape against corrosion with 4 layers on primer

DVGW